



ABUJA MOU

## MEMORANDUM OF UNDERSTANDING ON PORT STATE CONTROL FOR WEST AND CENTRAL AFRICAN REGION (ABUJA MoU)

**AMOU-F-CIC-013-A**

AMoU Concentrated Inspection Campaign on Fire Safety (Questionnaire)

<b>CIC on FIRE SAFETY</b>			
<b>Inspection Authority</b>			
<b>Ship Name</b>		<b>IMO Number</b>	
<b>Date of Inspection</b>		<b>Inspection Port</b>	

**QUESTIONS 1 TO 10 ANSWERED WITH A “NO” MUST BE ACCOMPANIED BY A RELEVANT DEFICIENCY ON THE REPORT OF INSPECTION.**

No.	Item	Yes	No	N/A	Detention
1*	Are the emergency escape routes maintained in a safe condition? (07120/04103)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2*	Are the fire doors maintained in good working condition? (07105)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3*	Has the fixed fire detection and fire alarm systems, been periodically tested in accordance with the requirements of the Administration? (07106)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4*	Are ventilation closing appliances capable of being closed? (07116)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5*	Are the means of control for power ventilation of machinery spaces operable from two grouped positions? (07116)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6*	Can each fire pump deliver at least the two required jets of water? (07113)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7*	Are the means of control provided in a position outside the machinery space for stopping ventilation and oil transfer equipment operational? (07114)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8*	Is the room for the fixed gas fire extinguishing medium used only for this purpose? (07109)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9*	Are the valves used in the fire main line operational? (07110)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10*	Where a fire drill was witnessed, was it found to be satisfactory? (04109/07125)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Note: If “No” is ticked for questions marked with an asterisk “\*”, the ship may be considered for detention.